



Certificate of Compliance

Certificate: 2645180

Master Contract: 255045

Project: 2645180

Date Issued: September 26, 2013

Issued to: SHANGHAI CHINT POWER

SYSTEMS CO.,LTD
3255 Si Xiang Rd
Songjiang District,
Shanghai, Shanghai 201614
China
Attention: Mr. Danson Chen

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Kyle Song

Issued by: Kyle Song

PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment
CLASS 5311 89 - POWER SUPPLIES - Distributed Generation - Power Systems Equipment
- Certified to U.S. Standards

Utility Interactive Inverter, Model CPS SCA23KTL-DO/US-480 and CPS SCA28KTL-DO/US-480, permanently connected.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-01 - General Use Power Supplies

UL Std. No.1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources(January 28, 2010)

Note: Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of ANSI/IEEE 1547 (2003) and ANSI/IEEE 1547.1 (2005). This product's software for isolation monitor interrupter has been evaluated to the requirements of UL Standard No. 1998



Supplement to Certificate of Compliance

Certificate: 2645180

Master Contract: 255045

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2645180	Sep 26, 2013	Utility Interactive Inverter, Model CPS SCA23KTL-DO/US-480 and CPS SCA28KTL-DO/US-480.(C/US)