



Certificate of Compliance

Certificate: 70097583

Master Contract: 255045

Project: 70207529

Date Issued: 2019-01-29

Issued to: SHANGHAI CHINT POWER SYSTEMS CO.,LTD
3255 Si Xian Rd
Songjiang District,
Shanghai, Shanghai 201614
CHINA
Attention: Huan Cai

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and US Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Rohana Yang
Rohana Yang

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Power Converter System (Utility Interactive Inverter, Grid Support), Model CPS ECB30KTL-O/US, permanently connected, bi-directional for use with battery management system.

Note:

1. For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-01 - General Use Power Supplies

*UL Std. No. 1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (January 28, 2010)



Certificate: 70097583

Master Contract: 255045

Project: 70207529

Date Issued: 2019-01-29

***Note:**

1. Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011) , IEEE 1547.1a-2015, California Electric Rule 21 and Supplement SA.
2. Functional safety has been evaluated according to UL 1998-Edition 3.



Supplement to Certificate of Compliance

Certificate: 70097583

Master Contract: 255045

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70207529	2019-01-29	Update to report 70097583 to include the Grid Support Function according to California Rule 21 requirement for model CPS ECB30KTL-O/US.
70097583	2017-03-13	Power Converter System (Utility Interactive Inverter), Model CPS ECB30KTL-O/US(C/US).