



# Certificate of Compliance

**Certificate:** 70172159

**Master Contract:** 255045

**Project:** 80046607

**Date Issued:** 2020-06-17

**Issued to:** SHANGHAI CHINT POWER SYSTEMS CO., LTD  
3255 Si Xian Rd  
Songjiang District,  
Shanghai, 201614  
CHINA  
**Attention:** Huan Cai

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



*Kyle Song.*

**Issued by:** Kyle Song

## **PRODUCTS**

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Grid Support Transformerless Utility Interactive Inverter, Models CPS SCH100KTL-DO/US-600, CPS SCH125KTL-DO/US-600, CPS SCH100KTL-AIO/US-600, CPS SCH125KTL-AIO/US-600, permanently connected.

## **Notes:**

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.



**Certificate:** 70172159  
**Project:** 80046607

**Master Contract:** 255045  
**Date Issued:** 2020-06-17

---

### **APPLICABLE REQUIREMENTS**

- CSA C22.2 No. 107.1-16 - Power Conversion Equipment
- \*UL 1741 - Inverters, Converters, Controllers and Interconnection System  
Equipment for Use With Distributed Energy Resources (Second Edition, Revision dated February 15, 2018)
- UL1741 CRD - Non-Isolated EPS Interactive PV Inverters Rated Less Than 30Kva (Dated  
April 26, 2010)
- UL1741 CRD - Grid Support Utility Interactive Interoperability Optional Functions: Prevent  
Enter Service and Limit Active Power (CA Rule 21, Phase 3, functions 2 and 3) (Dated October 22, 2019)

\*Note: Conformity to UL 1741 (Second Edition, Revision February 15, 2018) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011), IEEE 1547.1a-2015, California Rule 21 and Supplement SA 8 - 18.